



United States Steel Corporation
Clairton Works
400 State Street
Clairton, PA 15025

J Hagedorn

RECEIVED

January 17, 2017

JAN 24 2017

Air Protection Division

Ms. Karen M. Sagel
Allegheny County Health Department
Department of Air Quality
301 Thirty-Ninth Street
Pittsburgh, PA 15201

Subject: USS Reference Number: 17-0004
ACHD Reference Number: 20486
SCOT Plant
USS Clairton Works

Dear Karen M. Sagel,

The attached form confirms our verbal report of the subject incident and satisfies the requirements of paragraph IV.8 of the Title V operating permit #0052 as issued on March 27th 2012.

I certify that based on the information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete. Any questions concerning this matter should be referred to Jonelle S. Scheetz at 412-233-1015.

Sincerely,

Steven J. Zelenski
Acting Plant Manager
Clairton Works

CC: James W. Hagedorn (USEPA)

NOTICE OF OUTAGE OF EQUIPMENT
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 17-0004
ACHD Reference Number: 20486
2. Date & Time of Breakdown: Date: 01/12/17 Time: 0930 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: SCOT Plant
5. BAPC Permit Number (if applicable): 0052
6. Location: Clairton, PA
7. Nature and cause of breakdown: The SCOT Plant was taken out of service to switch between reactors.
8. Identification of Emissions:
 - A. Type(s) (CO, NOX, SO₂, Particulates, Hydrocarbons, etc.)
Elevated H₂S at the incinerator stack, causing increased SO₂ at point of combustion.
 - B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). SO₂ is an eye, nose, and throat irritant.
 - C. Amount of each type emitted (or likely to be emitted).
Light to Moderate
9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).
The SCOT Plant will return to service upon completion of the task.
10. Facility back in operation - Date: Time: hours

Reviewed by Jonelle S. Scheetz Date 1/16/17
Jonelle S. Scheetz
Environmental Control Engineer Phone: 412-233-1015